



# INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

*We Protect Hoosiers and Our Environment.*

100 N. Senate Avenue • Indianapolis, IN 46204

(800) 451-6027 • (317) 232-8603 • [www.idem.IN.gov](http://www.idem.IN.gov)

Michael R. Pence  
Governor

Thomas W. Easterly  
Commissioner

October 20, 2015

Mr. Jeff Harter  
Plant Leader Environmental  
IPL Petersburg Station  
6925 N. State Road 57  
P.O. Box 436  
Petersburg, IN 47567-0436

Re: Revised Inspection Summary /  
Violation Letter  
IPL Petersburg Station  
Plant ID: T125-00002  
Petersburg, Pike County

Dear Mr. Harter:

On July 14<sup>th</sup>, 2015, Patrick Austin of the Indiana Department of Environmental Management, Office of Air Quality, conducted an inspection of Indianapolis Power & Light Co., Petersburg Generating Station, located in Petersburg, Indiana. The inspection was conducted pursuant to IC 13-14-2-2. For your information, and in accordance with IC 13-14-5, a summary of the inspection is provided below:

Type of Inspection:	<input checked="" type="checkbox"/> Commitment
	<input type="checkbox"/> Surveillance
	<input type="checkbox"/> Complaint
	<input type="checkbox"/> Other
Results of Inspection:	<input type="checkbox"/> No violations were observed
	<input type="checkbox"/> Violations were observed but corrected during the inspection.
	<input checked="" type="checkbox"/> Violations were observed.
	<input type="checkbox"/> Additional information/review is required to evaluate overall compliance.
	<input type="checkbox"/> Violations were observed that will result in an enforcement action.
	<input type="checkbox"/> Other

During the inspection, Mr. Austin determined that your company had failed to submit the facility's Annual Compliance Certification (ACC) report in a timely manner, in violation of permit condition B.9(a) of permit no. T125-34687-00002. Please ensure that future ACC reports are submitted in a timely fashion.



Mr. Jeff Harter  
IPL Petersburg Station  
Page Two

A visible emission evaluation of Unit 3 was completed at 5:12 p.m. on the day of the inspection, resulting in an exceedance of both the NSPS opacity limit (20%) and section C.2 overall source opacity limit (40%). The exceedance of the NSPS and overall source limit for opacity noted above constitute a violation of permit sections D.2.2 and C.2, respectively.

The Compliance Data Section (CDS) of the Office of Air Quality will be evaluating any violations related to monitored excess emissions or continuous monitor downtime and may take additional action related to those as merited.

OAQ has referred these violations to EPA to pursue. Should you have any questions, please contact Mr. Austin via telephone at (317) 234-349 or via e-mail at [paustin@idem.IN.gov](mailto:paustin@idem.IN.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "Lynne Sullivan".

Lynne Sullivan, Chief  
Air Compliance & Enforcement Section 2  
Office of Air Quality

cc: Pat Austin  
David Holder  
Ethan Chatfield, US EPA Region 5

ACES 188652  
188654